

# Certificate of Compliance



This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

You have been awarded:

## **Intertek WH US + C Mark for Category B - Doors - Additional Edge-sealing System Required**

Standards: CAN / ULC S104 (2015), UL 10(c) (2016), UL 10(b) (R2015), NFPA 252 (2017)

Certificate number: WHI20 - 29930405

**Organization:** Zhejiang Dreamroom Industry and Trade Co., Ltd  
No. 133, Huadu Road, Chengxi New Industry Zone  
Yongkang City, Zhejiang Province 321300  
China

**Product:** Zhejiang Dreamroom-3/4 hour Single Swing Wooden Composite Door, model (DM-UL060D)

*Spec ID:* 52082

*Fire Rating:* 45 Min PP Category B Door


*Listing Information:* See following page(s)

**Certification body:** Intertek Testing Services NA, Inc.

**Initial registration:** December 1, 2020

**Date of expiry:** December 1, 2025

**Issue status:** 1

Authorized By:   
**Jean-Philippe Kayl, Director of Certification**

**Intertek Testing Services NA, Inc.**  
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA  
Phone: 847-439-5667 Fax: 847-439-7320

[www.intertek.com](http://www.intertek.com)

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the reader or user should contact Intertek to validate its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

# LISTING INFORMATION

## FIRE RESISTANT PRODUCTS & COMPONENTS

### CATEGORY B DOORS - ADDITIONAL EDGE-SEALING SYSTEM REQUIRED

#### PRODUCT COVERED

3/4-hour Single Swing Wooden Composite Door

Model: DM-UL060D

Door Size (single swing):

Maximum Width: 1134 mm  
Maximum Height: 2362 mm  
Minimum Thickness: 45 mm

#### PRODUCT DESCRIPTION

Hardware Limitations:

Mortise lock with minimum latch bolt throw 3/4 in.  
Maximum backset: 70mm  
Minimum one single point standard latching on the leaf.

Configuration	Size
Single Swing	- 1134mm wide x 2362mm high x 45mm thick

Standard Pairs - Not allowed.

Double Egress- Not allowed.

For use with ZHEJIANG DREAMROOM 3/4-hour Wooden Frame ( Model of DM-UL060D) only.

ZHEJIANG DREAMROOM 3/4-hour Single Leaf Wooden Composite Door (Model of DM-UL060D) was fastened to an aerated concrete or masonry wall by steel bar with nail. The maximum clearance between the wall and the frame is 10mm and the clearance is filled with mineral wool clad with quick-setting cement.

The product noted above has been tested and qualified 3/4-hour positive pressure fire rated applications per UL 10C, NFPA 252, and 3/4-hour neutral pressure fire rated applications per CAN/ULC-S104, UL 10B.